

USARC G-6 Addendum to ARNEC CHG3 Telecommunications Outlet Table

NOTE: Provide Wireless Access Point (WAP) outlets for each building/space per ARNEC Section 2.4.9

Space Name/Type/Function	Outlet Type	Jack Qty.	Outlet Qty.	Notes
Administrative Offices (Full-Time and Exclusive)	Standard	1	2	1 outlet for workstation and one outlet on opposite or adjacent wall
Armorer's Room	Standard	1	2	1 outlet for workstation and one outlet on opposite or adjacent wall
Arms Vault	IDS	Provide per ARNEC section 2.8		
Arms Vault	Wall Phone	1	1	Locate interior wall opposite to Arms Vault door swing immediately adjacent to Arms Vault Door opening
Assembly Hall	Standard	2	1	Locate near instructor location
Battery Room	None Required	N/A	N/A	N/A
Break Area	None Required	N/A	N/A	N/A
Career Counselor Office (ARCC)	Standard	1	2	1 outlet per workstation
Chair and Table Storage	None Required	N/A	N/A	N/A
Circulation	None Required	N/A	N/A	N/A
Comsec Storage	Standard	1	1	Locate immediately adjacent to planned location of IPS container
Conference Room	Standard	1	1	Locate on same wall as television
Controlled Waste Storage	None Required	N/A	N/A	N/A
Controlled Waste Storage	None Required	N/A	N/A	N/A
Custodial/Janitorial	None Required	N/A	N/A	N/A
Distance Learning Center	Standard	1	Varies	Coordinate locations and quantities with Distance Learning Manager
Electrical	None Required	N/A	N/A	N/A
Elevator	Provide per UFC 3-490-06 Elevators			
Elevator Equipment Room	Provide per UFC 3-490-06 Elevators			
Entrance Facility	None Required	N/A	N/A	N/A
Facility Maintenance Storage	None Required	N/A	N/A	N/A

Family Support Office	Standard	1	2	1 outlet for workstation and one outlet on opposite or adjacent wall
Flammable Storage	None Required	N/A	N/A	N/A
Flammable Storage	None Required	N/A	N/A	N/A
Fluid Distribution Room	None Required	N/A	N/A	N/A
General Officer Suite	Standard	1	2	1 outlet for workstation and one outlet on opposite or adjacent wall
IT Work Space	Standard	1	Base on full length of work surface	Continuous metal raceway extending the full length of the work surface with telecommunications outlets at 6 in (150 mm) on center
Kitchen Administrative Office	Standard	1	2	1 outlet for workstation and one outlet on opposite or adjacent wall
Lactation Room	None Required	N/A	N/A	N/A
Learning Center	Standard	1	1	Locate on wall opposite entry door
Lobby	Wall Phone	1	1	Locate just inside main door on side wall
Mail Distribution Room	Standard	2	1	Locate adjacent to mail machine
Main Classroom	Standard	1	Varies	1 outlet per student location (Locate on wall if wall outlets can be Locate within 12 feet laterally of student seats, otherwise provide floor boxes (combined with power) for each student seat)
Main Classroom	Standard	2	1	Locate near instructor location
Male and Female Locker Rooms	Wall Phone	1	1	Locate just inside main entry door
Male and Female Toilets	None Required	N/A	N/A	N/A
Male and Female Toilets/Showers	None Required	N/A	N/A	N/A
Mechanical Room	ECBS	1	1	Locate near JACE device
Mechanical Room	Standard	1	1	1 outlet per workstation
Physical Readiness Training	Wall Phone	1	1	Locate just inside main entry door
Retention Office	Standard	1	2	1 outlet for workstation and one outlet on opposite or adjacent wall
Secondary Classroom	Standard	2	1	Locate near instructor location

Secret - Controlled Access Area (a.k.a. SIPR Café)	Provide per ARNEC section 2.7			
Shop Office	Standard	1	Varies	1 outlet per workstation
Shop Office	MFD	1	Varies	1 outlet for each Printer/MFD device
Simulator Room	Standard	1	2	One outlet Locate near the simulator pump and one on the wall behind the table
Special Equipment Alcove	None Required	N/A	N/A	N/A
Staging Area	None Required	N/A	N/A	N/A
Stairs	None Required	N/A	N/A	N/A
Storage Room	Standard	1	1	Locate near automated inventory device
Supply Office	Standard	1	4	1 outlet for workstation
Team Room	Standard	1	1	Locate on same wall as television
Team Room (SIPR-In-A-Box)	Standard	1	1	Locate immediately adjacent to planned location of IPS container
Telecommunications Equipment Room	None Required	N/A	N/A	N/A
Telecommunications Room	None Required	N/A	N/A	N/A
Tool and Parts Room	Standard	1	1	Locate near automated inventory device
Unit Commons (Benching Table)	Standard	1	1	Locate on nearest wall
Unit Commons (Full-Time Cubicle)	Standard	1	Varies	1 outlet per workstation
Unit Commons (Printer-Copier)	MFD	2	Varies	1 outlet for each Printer/MFD device
Unit Storage	Wall Phone	1	1	Locate just inside main interior door to adjacent hallway
Vending Alcove	None Required	N/A	N/A	N/A
Work Bays	Wall Phone	1	1	Locate just inside main interior door to adjacent hallway